



भारतीय विमानपत्तन प्राधिकरण
AIRPORTS AUTHORITY OF INDIA

No. AAI/ER/RTI/PIO/2025/20

Dated : 03/01/25

To
Shri Ravichandra Naidu,
Subject : Information under RTI Act. 2005.


Sir,

Reference is made to your RTI application no. AAIKO/R/T/24/00111 dated 05-12-24.

Enclosed herewith please find information which is received in respect of your above mentioned RTI application.

Encl : As above.

Sincerely Yours


03/01/2025

(H.S. Biswas)

General Manager(CNS-ER)/PIO-RHQ-ER,
NSCBI Airport, Kolkata-52

However, if you are not satisfied with the reply/information, you have the option to file an appeal within 30 days from the date of receipt of reply/information to the First Appellate Authority. The details of First Appellate Authority is given below :

To

Smt Nivedita Dubey, RED(ER)/First Appellate Authority (FAA),
Airports Authority of India, Regional Head Quarters,
Eastern Region, N.S.C B.I. Airport, Kolkata-700 052.

Dated: - 03th Jan 2025


The Public Information Officer (PIO)
Regional Headquarter (RHQ) – ER
Airports Authority of India
NSCBI Airport
Kolkata - 700052

Sub.: Reply under Right to Information Act, 2005- reg.

Sir,

Accordingly, information received from custodian is attached herewith for your kind information.

Regards.



(Jawed Akhter)
Off. Airport Director / PIO

Encl ;

1. Information copy
2. RTI application AAIKO/R/T/24/00111

निदेशक विमानपत्तन का कार्यालय जयप्रकाश नारायण अन्तर्राष्ट्रीय हवाई अड्डा पटना -800014

To
The Public Information Officer
Airports Authority of India
IPNI Airport, Patna-14

Date: 02/12/2024

Subject: Request for information under RTI Act, 2005 regarding Tender ID: 2024_AAI_212335_1

Kind. Attention: Mr. Shridhar Gupta SM (E-E)

Dear Sir/Madam,

We respectfully submit our observations regarding the technical evaluation for the tender referenced above. Upon review of the publicly available information, we have identified several discrepancies in the evaluation process, which may impact the fairness and accuracy of the results.

Kindly provide the following details to the email address: ravichandrannaidu@gmail.com

The following table summarizes our observations regarding the discrepancies as per GCR rule 2016.

Technical Evaluation Summary Table:

Sr.No	Contractor	Pyroguard Eng.	SVS Buildwel	Vimal Fire (Shootfire)	Comments/Objections
1	OEM as per Tender	Vivina	Siemens	Rotarex	3. Rotarex is not an approved make
2	Doc. Attach in Tender	480	416	148	
3	FM/UL/VDS component approval (as per clause 1.2 Specific Technical Req.)	Not Attached	Attached	Attached	1. Vivina has not attached any documents for UL/FM/VDS component approval. Note: How was the technical comparison done?
4	The complete system should be UL/FM/VDS certified (as per clause no. xxiii of 1.3 Specific Technical Req.)	Attached	Attached	Attached	
5	PESO (Compliance) Approved Valve	Not Attached	Not Attached	Not Attached	1. None of the bidders attached PESO-compliant valve certificates.

Information Under RTI Act. 2005, Regarding Tender Id:- 2024 AAI 212335 1

RTI Reply

Sr. No.	Contractor	Pyroguard Engg.	SVS Buildwel	Vimal Fire (Shootfire)	Comments/Objections	AAI Reply
1	OEM as per Tender	Vivina	Siemens	Rotatex	3. Rotarex is not an approved make	Vimal Fire (Shootfire) is In Approved make of AAI. Hence, considered.
2	Doc. Attach in Tender	460	416	148		
3	FM/JL/VDS Component approval (as per clause 1.2 specific Technical Req.)	Not Attached	Attached	Attached	1. Vivina has not attached any documents for UL/FM/VDS component approval Note: How was the technical comparison done?	Vivina has submitted VDS certificates
4	The complete system should be UL/FM/VDS certified (as per clause no. xiii of 1.3 Specific Technical req.)	Attached	Attached	Attached		
5	PESO (Compliance) Approval Value	Not Attached	Not Attached	Not Attached	None of the bidders attached PESO-compliant valve certificates. Note: How was the technical comparison done?	Through Shortfall of CPP, Bidders have submitted undertaking of complying /submit the UL/CCOE/PESO Certificate for all the components before supply of material.





Information Under RTI Act. 2005, Regarding Tender Id:- 2024 AAI 212335 1

RTI Reply

	Attached	Not Attached	Not Attached		Through Shortfall of
6	PESO (Compliance) Approval Cylinder	Attached	Not Attached	Not Attached	Through Shortfall of CPP, Bidders have submitted undertaking of complying /submit the UL/CCOE/PESO Certificate for all the components before supply of material.
7	PESO (Compliance) Approval Filing Station	Attached	Not Attached	Not Attached	Through Shortfall of CPP, Bidders have submitted undertaking of complying /submit the UL/CCOE/PESO Certificate for all the components before supply of material.
8	OEM as per AAI approval make list also submit import documents in their name i.e. Clean Agent GAS FK-5-1-12 in Technical Bid	Attached	Not Attached	Not Attached	Through Shortfall of CPP, Bidders have submitted undertaking of complying /submit the UL/CCOE/PESO Certificate for all the components before supply of material.

Shridhar
SM(E-E)

Shridhar Gupta
SM(E-E)
AAI, JPNi Airport
Patna-14

- o Rotarex, included as an OEM by one bidder, is not listed in the approved makes. It is unclear how this was considered valid during evaluation.
3. **Import Document Requirement for Clean Agent Gas (Clause 6):**
- o Some participants, such as SVS Buildwell/Siemens and Vimal Fire, have not submitted import documents for Clean Agent Gas FK-5-1-12, as mandated in the technical bid requirements.
4. **Lack of Technical Consistency in Evaluation:**
- o Based on the evaluation criteria provided in the tender, the acceptance of incomplete or missing documentation raises questions about the consistency of the technical comparison process.

Make List:

VIVINA, SIEMENS, SHOOTFIRE (VIMAL)/LIFEGUARD (UNITED FIRE), CEASEFIRE KALPEX (KALPATARU)/FOAMTECH

Observation: Rotarex is not in the Approved Makes. How was this considered?

We respectfully request the Technical Evaluation Committee to review these observations and reassess the evaluation results to ensure that all participants are judged equitably based on the tender's stated criteria.

We trust that the AAI will uphold its commitment to transparency and fairness in the procurement process & recall the Tender.

Yours sincerely

Thanks & regard



Ravichandran Naidu (Director)

ravichandranaidu0@gmail.com

Mobile No. 7502321366.

Sr.No	Contractor	Pyroguard Eng.	SVS Buildwel	Vimal Fire (Shootfire)	Comments/Objections
					Note: How was the technical comparison done?
8	PESO (Compliance) Approved Cylinder	Attached	Not Attached	Not Attached	2. SVS Buildwel/Siemens and Vimal Fire have not attached PESO-compliant cylinder certificates. Note: How was the technical comparison done?
7	PESO (Compliance) Approved Filling Station	Attached	Not Attached	Not Attached	3. SVS Buildwel/Siemens and Vimal Fire have not attached PESO-compliant filling station certificates. 3. Note: How was the technical comparison done?
9	OEM as per AAI approved make list also submit import documents in their name i.e Clean Agent Gas FK-5-1-12 in Technical Bid	Attached	Not Attached	Not Attached	2. SVS Buildwel/Siemens and Vimal Fire have not submitted Clean Agent Gas FK-5-1-12 import documents. Note: How was the technical comparison done?

Observations:

1. Non-Compliance with Technical Requirements:

○ it appears that some participants have been qualified despite failing to submit essential certifications/documents, as outlined in the tender requirements. For example:

- *Clause 1.2 (FM/UL/VDS Component Approval):* Vivina has not submitted documents for FM/UL/VDS component approval.
- *Clause xxiii of 1.3 (Complete System Certification):* Certain bidders lack PESO-compliant approved valves, cylinders, or filling stations.

2. Approved OEM List Compliance: